




DETAIL A




TOP VIEW



LEFT SIDE



FRONT VIEW



RIGHT SIDE

# NOTES:

- A. Quantity:
- B. Material: H.R. Carbon Steel
- C. Tank: 10 GA w/ 10 GA Top.
- D. Design & Operating Pressure: Atmospheric.
- E. Design & Operating Temperature: Ambient.
- F. Tank to be Built & Labeled per U.L. Spec. #142.
- G. Tank to Bear Manufacturers & U.L. Labels Only.
- H. Tank to be Air Tested with Water & Soap Suds Solution.
- I. Interior: Remove Weld Slag (Ship Clean & Dry).
- J. Exterior: Gray primer included; see Sales Order for top coat.
- K. All Fittings to be Protected for Shipment.
- L. Customer has the Responsibility to Verify All Dimensions.

\*All pages of this Schedule A are incorporated by reference and are a part of the additional terms of the Master Terms & Conditions of Sale.  
[www.newberrytanks.com/masterterms.pdf](http://www.newberrytanks.com/masterterms.pdf)

## APPROVAL FOR CONSTRUCTION SCHEDULE A - MASTER TERMS & CONDITIONS OF SALE\*

- ☐ APPROVED AS DRAWN.
- ☐ APPROVED WITH NOTED CHANGES, CONSTRUCTION WILL BE SCHEDULED WHEN SIGNED DRAWING AND CONFIRMED ORDER ARE RECEIVED.
- SIGNATURE \_\_\_\_\_
- DATE: \_\_\_\_\_

## NOZZLE SCHEDULE

ITEM	SIZE	RATING	TYPE	MATL	PROJ IN	PROJ OUT	REMARKS
A	3/4"	N.P.T.	W.F.	C.S.	STD.	STD.	DRAIN
B	2"	N.P.T.	W.F.	C.S.	STD.	STD.	
C	6"	N.P.T.	H. CPL.	C.S.	STD.	STD.	EMERGENCY VENT OPENING

## SALES ORDER #



860 Johnson Drive  
 Delano, MN 55328  
[www.fluidall.com](http://www.fluidall.com)

### VESSEL DESCRIPTION:

1,000 GALLON BULK SINGLE WALLED TANK

CUSTOMER:			P.O.#	
DATE:	SCALE:	DWG.#	SSWBT1000	
			DRAWN BY:	TC
			CHKD. BY:	TB